

#### Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16 D-32758 Detmold

Germany Fon: +49 5231 14-0

Fax: +49 5231 14-292083 www.weidmueller.com







The UPS control unit together with the associated battery module and the power supply unit form a complete DC UPS system. In normal operation, the input voltage from the UPS control unit is connected directly to the load. In the event of a mains failure (drop of the DC input voltage) the system switches instantly to battery operation. Once the mains supply has been restored, the system switches back to normal operation and the battery is fully recharged by the integrated charger.

Three relay outputs, as well as three additional active transistor outputs and a control input to lock battery operation, provide full remote control by means of SPS or DCS control. Numerous modes of operation and an easyto-use status display provide rapid fault diagnosis and optimum customisation to the application.

### General ordering data

Order No.	<u>9916280024</u>
Туре	CP-BBU 115-230VAC / 24VDC
Version	UPS control unit, 24 V
GTIN (EAN)	4032248217878
Qty.	1 pc(s).



### Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16 D-32758 Detmold Germany

Fon: +49 5231 14-0 Fax: +49 5231 14-292083 www.weidmueller.com

# **Technical data**

### **Dimensions and weights**

Tamanavaturaa			
Weight	950 g	Net weight	1,150 g
Height	127.5 mm	Depth	161 mm
Length	161 mm	Width	72.5 mm

### Temperatures

Operating temperature	-20 °C+50 °C	Storage temperature	-20 °C+85 °C

#### Input

Conductor connection system	Screw connection	Connection range	AWG26-12 (0.1-4.0 mm <sup>2</sup> )
Input current	1 A @ 115 V AC; 0.6 A @	Input frequency	
•	230 V AC		50/ 60 Hz
Input fuse		Input voltage (voltage mode input)	85265 V AC; 120300
•			V DC; typ. 115230 V AC
	2 A time-lag fuse (internal)		±10%
Surge protection	Varistor	Turn-on current limit	Thermistor

### output

Battery charging current	2 A	Battery voltage	27.3 V
Conductor connection system	Screw connection	Connection range	AWG26-12 (0.1-4.0 mm <sup>2</sup> )
Control at input voltage		Mains failure bridge-over time	for 115 V
	0.2%	AC	24 ms
Mains failure bridge-over time for 2	30 V	Max. residual ripple	
AC	190 ms		< 50 mV <sub>eff</sub>
Output current	Max. 15 A / max 9.0 A for	Output power	
	power supply unit		360 W
Output voltage	24 V	Output voltage type	DC

### **General data**

Building Width	72.5 mm	Building height	161 mm
Degree of efficiency at max. load	72%	Depth	127.5 mm
EMC standards	EN 55011, EN 55022, EN 55024, EN 61000-6-2, 3	Low Voltage Directive	73/ 23/ EWG
Operating temperature	-20 °C+50 °C	Standards	DIN EN 50178, DIN EN 60950, IEC950
Status indication	Green LED (full charge): battery voltage > 29.5 V DC, Yellow LED (low battery): battery voltage < 22 V DC, Yellow LED (charging): BBU is loading battery, Red LED (error): no AC input voltage, Red LED (reversed battery): battery poles are reversed, LED red (battery open): no battery	Switching frequency	

### **Insulation coordination**

Weight

Humidity at operating temperature	20 to 85% RH without	Humidity at storage temperature	
	condensation		20 to 90%
electrical isolation, I/O rail	3 kV	electrical isolation, input-earth	1.5 kV
electrical isolation, input-output	3 kV	electrical isolation, output-earth	0.5 kV

Creation date February 26, 2013 7:43:30 PM CET

is connected

950 g

100 kHz



Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16 D-32758 Detmold

Germany

Fon: +49 5231 14-0 Fax: +49 5231 14-292083 www.weidmueller.com

## **Technical data**

### **Signalling**

Status indication Green LED (full charge):

battery voltage > 29.5 V DC, Yellow LED (low battery): battery voltage < 22 V DC, Yellow LED (charging): BBU is loading battery, Red LED (error): no AC input voltage, Red LED (reversed battery): battery poles are reversed, LED red (battery open): no battery is connected

### **Approvals**

Institute (CSA) Certificate No. (CSA)

1

200039-1753619CB

#### Classifications

ETIM 2.0	EC001039	ETIM 3.0	EC001039
UNSPSC	30-21-18-01	eClass 4.1	27-24-04-10
eClass 5.1	27-04-90-02	eClass 6.0	27-04-90-04
eClass 7.0	27-04-90-02		

### **Approvals**

Approvals



### **Downloads**

Declaration of Conformity <u>ECC1628\_02\_09.pdf</u>



Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 16 D-32758 Detmold Germany

Fon: +49 5231 14-0 Fax: +49 5231 14-292083 www.weidmueller.com

## **Drawings**

### **Electric symbol**

